



**BILL OF MATERIAL**

ITEM	DESCRIPTION	UNIT	QUANTITY
1	CONCRETE, MIX NO. 1	CU. YD.	AS REQUIRED
2	BEND, 36" RADIUS PVC DUCT	EACH	AS REQUIRED
	$\left. \begin{array}{l} 3" \\ 4" \\ 5" \\ 6" \end{array} \right\}$		
3	SCREW 2", WASHER ATTACHED	BOX	AS REQUIRED
4	STRAP, PERFORATED GALVANIZED STEEL	ROLL	AS REQUIRED

**INSTALLATION INSTRUCTIONS**

- (A) CONCRETE ENCASEMENT OF CONDUIT WILL END AFTER INCLUDING JOINT BETWEEN DUCT BEND(S) AND DUCT EXTENDING AWAY FROM POLES.
- (B) FASTEN END OF DUCT BEND(S) TO POLE WITH STRAP. (SEE DETAIL "A" OR "B").
- (C) SECURE DUCT BEND(S) AWAY FROM TRAFFIC FLOW IF POSSIBLE AND INSIDE CURBSIDE TANGENT TO POLE. (SEE DETAIL "A" OR "B").
- (D) FILL IN AROUND BEND(S) WITH CLEAN COMPACTED BACKFILL.
- (E) COORDINATE LOCATION OF CONNECTION(S) WITH CONCERNED OVERHEAD AND UNDERGROUND SUPERVISION.

	APPROVED:  CHIEF, CONDUIT DIVISION	<b>CITY OF BALTIMORE</b> <b>DEPARTMENT OF TRANSPORTATION</b> <b>CONDUIT DIVISION</b>	ISSUED	REVISED	REVISED	
	 DIRECTOR, DEPARTMENT OF TRANSPORTATION	<b>CONDUIT POLE CONNECTION</b> <b>SINGLE, DOUBLE</b> <b>AND TRIPLE</b>	8 / 2010	<b>STANDARD NO.</b> <b>BC 824.05</b>		
			SCALE : NONE	SHEET 1 OF 1		